

Common Errors

- no answer to yes-no-n/a
- incomplete row
- no answer additional comments
- illegible
- Complete documentation said to be onsite when not.
- logically inconsistent answers
- wrong standard
- battery testing not on full load
- confusion of remarks/deficiencies/recommendations
- incorrect/incomplete labelling passed
- no record of time tested
- no record of test reading
- abbreviations/jargon in remarks



Common Errors

- Smoke detector sensitivity testing – missing info/incomplete
- Duct smoke detector testing – missing pressure differential
- Dry system trip – pressure differential measurements
- Water flow testing – document all flow switch testing
- no building representative name
- no signature
- fraudulent technician signature
- incomplete Device Record
- C6 Legend must agree with Device Record
- No EOL voltage
- Follow 21 notes in Individual Device Record

